SS 15.1 - Systems for Communicating Evacuation

Address:		
Provided by (name):		
Equipment Register		
Make	Model	Location
1		
2		
3		
Performance/Installation Standard:	NZS 4512 Year AS 1851 Year AS2220:1985 Specifically Designed A Other (Historical)	
Inspections & Maintenance Standard:	NZS 4512 Year AS 1851 Year AS 2220: 1985 Specifically designed s	
As a minimum these inspections and maintenance procedures will be carried out:	Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required. See Below	
Inspection frequency and responsibility:	☐ Monthly ☐ Annual	Owner IQP Owner IQP
Reporting:	The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include: • Details of any inspection, test or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work. • A Form 12A provided by an IQP annually	

The information above is used to help generate the compliance schedule. If you are unsure of how to fill in this form please consult an IQP who is registered for the system above.