

SS 3.3 - INTERFACED FIRE OR SMOKE DOORS OR WINDOWS

Address:			
Provided by (name):			
Equipment Register			
No.	Make	Model	Location
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
Performance/Installation Standard:		<input type="checkbox"/> AS1851:2005 <input type="checkbox"/> Specifically Designed Alternate Solution <input type="checkbox"/> Other (Historical) _____	
Inspections and Maintenance Standard:		<input type="checkbox"/> Comp. Schedule Handbook and NZS 4178 <input type="checkbox"/> Comp. Schedule Handbook and AS1851:2005 <input type="checkbox"/> Specifically designed solution provide details separately	
As a minimum these inspections and maintenance procedures will be carried out:		Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required.	
Buildings Requiring daily maintenance: If selected daily inspections are required as stated below		<input type="checkbox"/> CS Purpose group <input type="checkbox"/> CL Purpose group <input type="checkbox"/> CO Purpose group <input type="checkbox"/> CM Purpose group <input type="checkbox"/> Building undergoing Building Work affecting an Auto Door	
Inspection frequency and responsibility:		<input type="checkbox"/> Daily	<input type="checkbox"/> Owner <input type="checkbox"/> IQP
		<input type="checkbox"/> Monthly	<input type="checkbox"/> Owner <input type="checkbox"/> IQP
		<input type="checkbox"/> Annually	<input type="checkbox"/> Owner <input type="checkbox"/> IQP
<i>Monthly Inspections (Daily if applicable)</i>		<ul style="list-style-type: none"> Doors should be inspected to ensure they can be opened and that they are not: 	

SS 3.3 - INTERFACED FIRE OR SMOKE DOORS OR WINDOWS

	<ul style="list-style-type: none"> ➤ locked ➤ barred ➤ blocked
<i>Annual Inspections</i>	<ul style="list-style-type: none"> • Operation of fail-safe devices in power outage situations • Operation of manual release provisions. • Connection to the building emergency warning system
Reporting:	<p>The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include:</p> <ul style="list-style-type: none"> • Details of any inspection, test or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work. • A Form 12A provided by an IQP annually

The information above is used to help generate the compliance schedule. If you are unsure of how to fill in this form please consult an IQP who is registered for the system above.