

# COMPLIANCE SCHEDULE DETAILS: SS 13/1 – MECHANICAL SMOKE CONTROL SYSTEMS



## PLEASE PROVIDE THE FOLLOWING INFORMATION

Date:

If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.

Applicant name:	Building name:
Site address:	Classified Use:
Existing Compliance Schedule Number(s): (if applicable)	Risk/purpose group:
	Fire hazard category:
	Total occupant load:

## SPECIFIED SYSTEM DESCRIPTION (ADDRESS THOSE ITEMS THAT APPLY)

Specified systems:	Existing	New	Modified	Removed
Type:	Dedicated smoke exhaust			
	Dedicated smoke control			
<p><b>(NOTE:</b> SS 13/1 does not apply to air handling systems required to function in smoke clearance mode during a fire. Such systems are covered under SS9)</p>				

Location plan for specified systems and records is attached:    Yes    No

No.	Equipment location	Make (main components)	Model
1			
2			
3			
4			
5			

## STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Performance/installation:	<p>AS 1668.2:2012 The use of ventilation and air-conditioning in buildings - Part 2: Mechanical ventilation in buildings</p> <p>AS/NZS 1668.1:1998 The use of ventilation and air-conditioning in buildings - Fire and smoke control in multi-compartment buildings</p> <p>AS/NZS 1668.1:2015 The use of ventilation and air conditioning in buildings - Part 1: Fire and smoke control in buildings</p> <p>Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)</p> <p>Other:</p>
---------------------------	---

## STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Inspections:	AS 1668:2012 AS 1851-2012 – Section 13 Other: _____	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)
Maintenance:	AS 1851-2012/Amdt 1-2016 AS 1851-2012 – Section 13 AS 1851-2005/Amdt 2-2008 AS 1851-2005 Other: _____	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided).

## INSPECTIONS, MAINTENANCE AND REPORTING (ADDRESS THOSE ITEMS THAT APPLY)

Minimum inspection and maintenance procedures:	Regular inspection and testing, and planned preventative maintenance and responsive maintenance, will be carried out in accordance with the nominated performance and inspection Standard/document, to ensure effective operation for the required duration in the event of a fire.
Inspection frequency and responsibility:	Depending on the type of installation and its performance standard/document: Specifically designed solutions: by IQP only Standard /other document:      Six-monthly by IQP only      Annually by IQP only
Reporting:	The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include: <ul style="list-style-type: none"><li>• Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work.</li><li>• Form 12A provided annually by the IQP.</li></ul>