COMPLIANCE SCHEDULE DETAILS: SS 3/2 - ACCESS CONTROLLED DOORS



PLEASE PROVIDE THE FOLLOWING INFORMATION								2.		
If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.										
Applicant name:					Building name:					
Site address:					Classified Use:					
Existing Compliance Schedule Number(s): (if applicable)					Risk/purpose group:					
					Fire hazard category:					
					Total occupant load:					
SPECIFIED SYSTEM DESCRIPTION (ADDRESS THOSE ITEMS THAT APPLY)										
Specified systems:			Existing New			odified	Moved			
Type:			Swipe card	access		Ke	ypad access			
			Proximity se	ensor access		Delayed egress				
			Other: (specify)							
Locatio	n plan for spec	cified system	s and records is	attached: Yes	s No					
No.	lo. Equipment location		Make (main components)			Model				
1										
2										
3										
4										
5										
STANI	DARDS (ADI	DRESS TH	HOSE ITEMS T	THAT APPLY)						
				stem has been inst	alled against a spe	ecific Stand	dard(s) / document	:.		
Perform installat		AS/NZS IEC 60839:2019 Alarm and electronic security systems Part 11-1: Electronic access control systems - system and components requirements Part 11-2: Electronic access control systems - application guidelines								
		Association of Building Compliance - code of practice for electro-mechanical controlled locking devices on egress doors, version 2.3 - august 2018								
		NZS 4239:1993 Automatic sliding door assemblies								
		AS 4085:1992 Automatic sliding door assemblies								
		Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)								
		Other:								

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

, ,		• • • • • • • • • • • • • • • • • • • •
Inspections:	NZS 4239:1993 Appendix A AS 4085:1992 Appendix A Manufacturers manual / procedures Other:	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)
Maintenance:	NZS 4239:1993 Appendix A AS 4085:1992 Appendix A Manufacturers manual / procedures Other:	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

INSPECTIONS, MAINTENANCE AND REPORTING (ADDRESS THOSE ITEMS THAT APPLY)

Minimum inspection and maintenance procedures:	Regular inspection and testing, and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard/document, to ensure: Occupants are not prevented from leaving the building and are able to leave the building without the use of swipe cards, keys or other security devices in the event or an emergency					
Inspection frequency and responsibility:	Depending on the type of installation and its performance standard/document: Specifically designed solutions: by IQP only Standard /other document: Daily: by owner / representative Monthly by owner / representative Six-monthly: by IQP only					
Buildings requiring daily maintenance:	CS purpose group CM purpose group	CL purpose group Risk group CA	CO purpose group Building work affecting an access controlled door			
Inspections & maintenance:	Automatic sliding / revolving doors: Doors which fall under the scope of SS 3/1 (Automatic sliding / revolving doors) and SS 3/2 will be inspected and tested for the appropriate items under SS 3/1 and SS 3/2. No Automatic sliding / revolving doors are present.					
Daily/monthly inspections:	Doors will be inspected to ensure they can be opened and that they are not: Locked Barred Blocked					
Six-monthly inspections:	The following inspections will be carried out when appropriate: Operation of fail-safe devices in emergency & power outage situations Connection to alarm system Any emergency power supply required to operate in the event of a power failure					
Biannual maintenance: Back up rechargeable batteries will be replaced every two years or when found inoperable.						

Reporting:

The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include:

- Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work.
- Form 12A provided annually by the IQP.