

COMPLIANCE SCHEDULE DETAILS: SS 14/1 – EMERGENCY POWER SYSTEMS



PLEASE PROVIDE THE FOLLOWING INFORMATION

Date:

If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.

Applicant name:	Building name:
Site address:	Classified Use:
Existing Compliance Schedule Number(s): (if applicable)	Risk/purpose group:
	Fire hazard category:
	Total occupant load:

SPECIFIED SYSTEM DESCRIPTION (ADDRESS THOSE ITEMS THAT APPLY)

Specified systems:	Existing	New	Modified	Removed
Type:	An engine alternator set for a sprinkler system pressure boost pump (SS 1)			
	Uninterruptible power supply for an emergency lighting system (SS 4)			
	An engine alternator set for provisions of electrical supply to passenger lifts (SS 8)			
	An engine alternator set for provision of electrical supply to a smoke clearance system (SS 13)			
	Other: [specify]			

Location plan for specified systems and records is attached: Yes No

No.	Equipment location	Make (main components)	Model
1			
2			
3			
4			
5			

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Performance/ installation:	NZS 6104:1981	NZS 4541
	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)	
	Other:	

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

Inspections:	NZS 6104:1981 Part 8	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided).
	Other:	
Maintenance:	NZS 6104:1981 Part 8	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided).
	Other:	

INSPECTIONS, MAINTENANCE AND REPORTING (ADDRESS THOSE ITEMS THAT APPLY)

Minimum inspection and maintenance procedures: Regular inspection and testing, and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard/document, to ensure:

- The system will operate as required in the event that the primary power supply fails

Inspection frequency and responsibility: Depending on the type of installation and its performance standard/document:

Specifically designed solutions: by IQP only	Weekly	Monthly
Standard /other document:	Six-monthly by IQP only	Annually by IQP only

Reporting: The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include:

- Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work.
- Form 12A provided annually by the IQP.

Interfacing: