COMPLIANCE SCHEDULE DETAILS: SS 4 - EMERGENCY LIGHTING SYSTEMS



PLEASE PRO	LEASE PROVIDE THE FOLLOWING INFORMATION					Date:		
(If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.)								
Applicant name:			Building name:					
Site address:				Classified Use:				
Existing Compliance Schedule Number(s): (if applicable			cable)	Risk/purpose group:				
				Fire hazard category:				
				Total occupant load:				
SPECIFIED SYSTEM DESCRIPTION (ADDRESS THOSE ITEMS THAT APPLY)								
Specified syster	ns:	Existing	Ne	PW .	Modified	Removed		
Type:	Emergency lighting system within the safe or open path of the building to facilitate evacuation. Emergency lighting installation for identification of the exit ways of a building to facilitate evacuation.							
Location plan for specified systems and records is attached: Yes No								
No. Equipr	pment location		Make (main components)		Model			
1								
2								
3								
4								
5								
STANDARDS	(ADDRESS TI	HOSE ITEMS T	HAT APPLY)					
Specifically design	gned solutions do	not apply if the sys	stem has been inst	talled against a specific	: Standard(s) / docume	ent.		
Performance/ installation:	7137 TNZ3 ZZ33.Z0 TO ETTICT GETTCY EVACUATION TIGHTLING TO DUILIAINGS							
	AS/NZS 2293.1:2018 Emergency evacuation lighting for buildings - system design, installation and operation					n and operation		
AS/NZS 2293:1995 Emergency evacuation lighting for buildings Part 1: System design, installation and operation Part 3: Emergency escape luminaries and exit signs								
	NZS 6742:1971 Code of practice for emergency lighting in buildings							
	NZS 6104:1981 Specification for emergency electricity supply in buildings; as modified by F6/AS1 Appendix C							
	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is compete do so. (Details provided)				ualifications, is competent to			
Other:								

Inspections:	AS/NZS 2293.2.2019 - Section 3 AS/NZS 2293.2.1995 - Section 2 and 3 NZS 6104:1981 — Part 8 — Section 802 Other:	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) Other:
Maintenance:	AS/NZS 2293.2.2019 - Section 3 AS/NZS 2293.2.1995 - Section 2 and 3 AS 2293.1.2005 - Section 8 NZS 6742:1971 – Clause 8 NZS 6104:1981 – Part 8 Other:	Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

INSPECTIONS, MAINTENANCE AND REPORTING (ADDRESS THOSE ITEMS THAT APPLY)					
Minimum inspection and maintenance procedures:	Regular inspection and testing and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure effective operation of the emergency lighting for the required duration in the event of a failure of the general lighting system.				
Inspection frequency and responsibility:	The system is connected to the building's emergency warning system therefore testing of the interface between the two systems will be carried out annually. Depending on the type of installation and its performance standard/document: Specifically designed solutions: by IQP only Six monthly by the IQP Standard / other document: Annually by IQP				
Reporting:	The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include:				

- Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work.
- Form 12A provided annually by the IQP