



Foul Sewer and Stormwater System

NOTES

1. In sealed areas the pipe are to be extended and an approved cast iron cover is to be placed flush with surface
2. A minimum of 300mm (Ø100mm) and 600mm (Ø150mm) straight pipe between all bends.
3. For Ø150mm property connections use a 150mm x 100mm reducing 'Y' junction

Not to scale



TYPICAL DETAIL BOUNDARY CLEANING EYE



Fig. D5
Rev. 7
Date 03/23