

SS15.1

Systems for Communicating Spoken Information to Facilitate Evacuation



Please provide the following information

Date

If you need help to complete this form, consult the system provider or an IQP who is registered for the system above

Applicant Name

Building Name

Site Address

Classified Use

Existing Compliance Schedule Number(s) (if applicable)

Risk/Purpose Group

Fire Hazard Category

Total Occupant Load

Specified System Description (address items that apply)

Specified Systems

Existing

New

Modified

Removed

Type

A building intercom system for use by the Fire Service

A public address system to facilitate staged evacuation

An emergency warning intercommunications system (EWIS)

Other

Location Plan for Specified Systems and Records is attached

Yes

No

| No | Equipment Location | Make (main components) | Model |
|----|--------------------|------------------------|-------|
| 1 | | | |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |

Standards (address items that apply)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document

Performance / Installation

AS 2220:1989 Emergency warning and intercommunication systems in buildings
Part 1: 1989 Equipment design and manufacture
Part 2: 1989 System design, installation and commissioning

AS 2220.1-1989/Amdt 2-1993 Emergency warning and intercommunication systems in buildings

AS 1851-2012 Routine service of fire protection systems and equipment

NZS 4512:2020 Fire detection and alarm systems in buildings.

AS 1851-2012/Amdt 1-2016 Routine service of fire protection systems and equipment

AS 1851:2005 Maintenance of fire protection systems and equipment

NZS 4512:2010 Fire detection and alarm systems in buildings.

NZS 4512:2003 Fire detection and alarm systems in buildings.

NZS 4512:1994 Fire alarm systems in buildings.

NZS 4561:1973 Specification for manual fire alarm systems.

NZS 4512:1997 Fire alarm systems in buildings.

NZS 4512:1981 Automatic fire alarm systems in buildings.

NZS 2211:1968 Manual fire alarm systems for use in buildings.

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Other

Inspections

NZS 4512:2010 – Part 6

NZS 4512:2003 – Part 6

NZS 4512:1997 – Part 6

NZS 4512:1994 – Part 6

NZS 4512:1981 – Part 4

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Other

Maintenance

NZS 4512:2010 – Part 6

NZS 4512:2003 – Part 6

NZS 4512:1997 – Part 6

NZS 4512:1994 – Part 6

NZS 4512:1981 – Part 4

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Other

Inspections, Maintenance and Reporting (address items that apply)

Minimum inspection & maintenance procedures

Regular inspection and testing and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection Standard/document, and to ensure the system will operate as required in the event of a fire.

Inspection frequency and responsibility

Depending on the type of installation and its performance standard/document:

Specifically designed solutions: by IQP only

Standard / another document:

Monthly: by IQP

Annually: by IQP

Reporting

The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include:

- Details of any inspection, test or preventative maintenance carried out, including dates, works under-taken, faults found, remedies applied and the person who performed the work.
- Form 12A provided annually by the IQP