

SS15/4

Signs for Communicating Information Intended to Facilitate Evacuation



Please provide the following information

Date

If you need help to complete this form, consult the system provider or an IQP who is registered for the system above

Applicant Name

Building Name

Site Address

Classified Use

Existing Compliance Schedule Number(s) (if applicable)

Risk/Purpose Group

Fire Hazard Category

Total Occupant Load

Specified System Description (address items that apply)

Specified Systems

Existing

New

Modified

Removed

Type

Signs to Facilitate Evacuation

Exit Sign

Directional Sign

No Exit Sign

Other

Location Plan for Specified Systems and Records is attached

Yes

No

No	Equipment Location	Make (main components)	Model
1			
2			
3			
4			
5			
6			
7			
8			
9			

Standards (address items that apply)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document

Performance / Installation

F8/AS1 Acceptable Solution for Clause F8 Signs
1 Jan 2017. Amd 4 ss 2.0, 3.0 & 4.0

F8/AS1 Acceptable Solution for Clause F8 Signs
14 Feb 2014. Amd 3 ss 2.0, 3.0 & 4.0

F8/AS1 Acceptable Solution for Clause F8 Signs
10 Apr 2012. 2nd Ed ss 2.0, 3.0 & 4.0

F8/AS1 Acceptable Solution for Clause F8 Signs
1 Sep 1993. Amd 1 ss 1.0, 2.0 & 3.0

F8/AS1 Acceptable Solution for Clause F8 Signs
1 Jul 1992. 1st Ed ss 1.0, 2.0 & 3.0

F6/AS1 Acceptable Solution for Clause F6 Visibility in escape routes
1 Jan 2017. Amd 4. ss 1.6

F6/AS1 Acceptable Solution for Clause F6 Visibility in escape routes
14 Feb 2014. Amd 3. ss 1.6

F6/AS1 Acceptable Solution for Clause F6 Visibility in escape routes
10 Oct 2011. Amd 2. ss 1.6

F6/AS1 Acceptable Solution for Clause F6 Visibility in escape routes
18 Oct 2007. 3rd Ed. ss 1.6

F6/AS1 Acceptable Solution for Clause F6 Visibility in escape routes
21 Jun 2007. 2nd Ed. Amd 1. Para. 1.1.3

F6/AS1 Acceptable Solution for Clause F6 Visibility in escape routes
1 June 2001. 2nd Ed. Para 1.1.3

F6/AS1 Acceptable Solution for Clause F6 Visibility in escape routes
1 Dec 1995 Amend 1. Para 6.1.2

F6/AS1 Acceptable Solution for Clause F6 Visibility in escape routes
1 Jul 1992. 1st Ed. Para 6.1.2

Other

Inspections

F8/AS? – Year

Monthly Inspections. Illuminated signs must be inspected to ensure they are of the correct type, present and in the right location, legible, illuminated.

Annual inspections. Signs not required to be illuminated must be inspected to ensure they are of correct type, present and in right location, legible and illuminated.

Standard relating to one or more of the specified systems 1–13. List Standard(s)

Other

Maintenance	<p>Signs shall be replaced if not of the correct type, replaced immediately should they be missing, refurbished before they become illegible. Defects in illuminated emergency signs shall be remedied immediately they are apparent</p> <p>Standard relating to one or more of the specified systems 1–13. List Standard(s)</p> <p>Other</p>
--------------------	---

Inspections, Maintenance and Reporting (address items that apply)

Minimum Inspection & Maintenance Procedures	Regular Inspection and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard of the associated system, and to ensure signs remain correctly-positioned and legible and where appropriate ensure the escape route is identified
--	--

Inspection Frequency & Responsibility	<p>Depending on the type of installation and its performance standard/document</p> <p>Specifically designed solutions: by IQP only</p> <p>Standard /other document</p> <p>Daily by Owner / representative (for Risk group CA / Purpose groups CS, CL, CO, CM)</p> <p>Monthly by IQP only (for other Risk group / Purpose groups)</p> <p>Six Monthly by IQP only (for other Risk group / Purpose groups)</p> <p>Annually by IQP only</p>
--	---

Inspections & Maintenance	<p>Monthly inspections</p> <p>Illuminated & photoluminescent signs will be inspected to ensure they are</p> <ul style="list-style-type: none"> • The correct type • Present and in the right locations • Legible • Performing as required e.g., illuminated signs are illuminating • All dedicated light source positions remain unaltered and in working order and clean <p>Annual inspections</p> <p>Signs not required to be illuminated will be inspected to ensure they are</p> <ul style="list-style-type: none"> • The correct type • Present and in the right locations • Legible <p>Signs required to be illuminated will be tested to ensure they</p> <ul style="list-style-type: none"> • Remain illuminated in the event of a failure of the main lighting supply, for the same duration as required by Building Code Clause F6 Visibility in Escape Routes
--------------------------------------	--

Reporting	
<p>The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include</p>	
<ul style="list-style-type: none"> • Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work. • Form 12A provided annually by the IQP 	