

**Please provide the following Information**

Date

*If you need help to complete this form, consult the system provider or an IQP who is registered for the system above*

Applicant Name

Building Name

Site Address

Classified Use

Existing Compliance Schedule Number(s) (if applicable)

Risk/Purpose Group

Fire Hazard Category

Total Occupant Load

**Specified System Description (address items that apply)**

*Specified Systems*

Existing

New

Modified

Removed

Type

Corridor pressurisation system

Stairwell pressurisation system

Other

Location Plan for Specified Systems and Records is attached

Yes

No

No	Equipment Location	Make (main components)	Model
1			
2			
3			
4			
5			
6			
7			
8			

## Standards (address items that apply)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document

### Performance / Installation

AS/NZS 1668:1:2015 The use of ventilation and air-conditioning in buildings.  
Part 1: Fire and smoke control in buildings

AS/NZS 1668:1998 The use of ventilation and air-conditioning in buildings  
Part 1: Fire and smoke control in multi-compartment buildings

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Other

### Inspections

AS 1851:2012

AS1851:2005

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Other

### Maintenance

AS 1851:2012

AS1851:2005

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Other

## Inspections, Maintenance and Reporting (address items that apply)

### Minimum inspection & maintenance procedures

Regular inspection and testing and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required in the event of a fire

### Inspection frequency and responsibility

Depending on the type of installation and its performance standard/document:

Specifically designed solutions: by IQP only

Standard / another document: AS 1851 by IQP only

### Reporting

The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include:

- Details of any inspection, test or preventative maintenance carried out, including dates, works under-taken, faults found, remedies applied and the person who performed the work.
- Form 12A provided annually by the IQP