

# SS6 Riser Mains



Please provide the following information

Date

*If you need help to complete this form, consult the system provider or an IQP who is registered for the system above*

Applicant Name

Building Name

Site Address

Classified Use

Existing Compliance Schedule Number(s) (if applicable)

Risk/Purpose Group

Fire Hazard Category

Total Occupant Load

## Specified System Description (address items that apply)

Specified Systems	Existing	New	Modified	Removed
Type	Dry Riser Charged Riser Other			

Location Plan for Specified Systems and Records is attached	Yes	No
-------------------------------------------------------------	-----	----

No	Equipment Location	Make (main components)	Model
1			
2			
3			
4			
5			

## Standards (address items that apply)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document

Performance / Installation
NZS 4510:2008 Fire hydrant systems for buildings
NZS 4510:1998 Fire hydrant systems for buildings
NZS 4510:1978 Code of practice for riser mains for fire service use
Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Other

#### **Inspections**

NZS4510:2008 – Part 9

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Other

#### **Maintenance**

NZS4510:2008 – Part 9

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)

Other

#### **Inspections, Maintenance and Reporting (address items that apply)**

##### **Minimum inspection & maintenance procedures**

Regular inspection and testing and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required in the event of a fire

##### **Inspection frequency and responsibility**

Depending on the type of installation and its performance standard/document:

Specifically designed solutions: by IQP only

Standard / another document: NZS 4510: IQP only

##### **Reporting**

The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include:

- Details of any inspection, test or preventative maintenance carried out, including dates, works under-taken, faults found, remedies applied and the person who performed the work.
- Form 12A provided annually by the IQP